

CERTIFICATE OF COMPLIANCE

Certificate Number 20170425-EX15958
Report Reference EX15958-20170424
Issue Date 2017-APRIL-25

Issued to: TIANJIN GALAXY VALVE CO LTD
15 Tianhua Rd
Balitai Industrial Area
Jinnan District
Tianjin 300350 CHINA

This is to certify that representative samples of BUTTERFLY VALVES
See addendum page for models.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 753, Standard for Alarm Accessories for Automatic Water-Supply Control Valves for Fire Protection Service
UL 38, Standard for Manual Signaling Boxes for Fire Alarm Systems
UL746A, Standard for Polymeric Materials – Short Term Property Evaluations
UL 1091 and ULC/ORD-C1091-1974, Standard for Butterfly Valves for Fire-Protection Service

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20170425-EX15958
Report Reference EX15958-20170424
Issue Date 2017-APRIL-25

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

UL

Model	Size, NPS	Body Type	Pressure Rating, psig	Indicator Post	Supervisory Switch*
Butterfly valve					
25GG	2.5, 2.5(76.1mm)	Groove	300	N/A	I/O
			250		
			200		
25W	2.5	Wafer	300		
			250		
			200		
25L	2.5	Lug	300		
			250		
			200		

UL, CNL

Model	Size, NPS	Body Type	Pressure Rating, psig	Indicator Post	Supervisory Switch*
Butterfly valve					
25GG	3,4,5(139.7mm),5,6(165.1mm),6,8,10,12	Groove	300	N/A	I/O
			250		
			200		
25W	3,4,5,6,8,10,12	Wafer	300		
			250		
			200		
25L	3,4,5,6,8,10,12	Lug	300		
			250		
			200		

Note: * I = Indoor installation; O = Outdoor installation

For the valve sizes 6 in. and smaller, configured with ratio 1:24 operator; for the valve sizes 8 in. and larger, configured with ratio 1:30 operator.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

